

CERTIFICATE OF COMPLIANCE

Certificate Number E494315
Report Reference E494315-20170712
Issue Date 2022-DECEMBER-09

Issued to: RED SKY LIGHTING, LLC
410 Main Street, Racine, WI 53403 United States

This certificate confirms that representative samples of LUMINAIRES FOR USE IN HAZARDOUS LOCATIONS
See next page for models.

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See next page for Standards for Safety.
Additional Information: See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Conformity Assessment Director
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E494315
Report Reference E494315-20170712
Issue Date 2022-DECEMBER-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards for Safety:

UL 844 Luminaires for Use in Hazardous (Classified) Locations
CSA C22.2 No. 137-M1981 Electric Luminaires for Use in Hazardous Locations
UL 8750 Light Emitting Diode (LED) Equipment for use in Lighting Product
UL 1598 and CSA C22.2 NO. 250.0 Luminaires
CSA C22.2 NO. 250.13 Light Emitting Diode (LED) Equipment for Lighting Applications
CSA C22.2 No. 30-M1986, Explosion-proof Enclosures for Use in Class I Hazardous Locations
CSA C22.2 No. 25-1966, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations

Class I, Division 2, Groups A, B, C and D, Class II, Division 1, Groups E, F and G –

BLM: Followed by -21, -40, -50 or -60: Followed by -120-277 or -347-480: Followed by -27K, -3K, -4K, -5K: Followed by -T2, -T3 or -T5: Followed by -H2: Followed by -CG -DG or -DP: Followed by -GRY, -BLK, -WHT or -BRZ: Followed by -PND, -YKE, -CEIL, -SN25, -SN90, -WL25, or -WL90: Followed by BLANK. (b7)

(b7)

- 1 – Fixture Series BLM - For all luminaires.
- 2 – Wattage, 21 - 21W, 40 - 40W, 50 - 50W, 60 - 60W.
- 3 – Voltage, 120-277 - 120-277V AC, 347-480 - 347-480V AC.
- 4 – Color Temperature, 5K - 5000K, 4K - 4000K, 3K - 3000K, 27K - 2700K.
- 5 – Beam Angle, T2 - Type II, T3 - Type III, T5 - 110° (non-optic).
- 6 – Hazloc Rating, H2 - C1D2 / C2D1 / C3.
- 7 – Lens, CG - Clear Glass, DG - Diffuse Glass, DP - Diffused Polycarbonate.
- 8 – Finish Color, GRY – Grey, BLK – Black, WHT – White, BRZ – Bronze.
- 9 – Mounting, PND – Pendant, YKE – Yoke, CEIL – Ceiling, SN25 - Stanchion 25°, SN90 - Stanchion 90°, WL25 - Wall 25°, WL90 - Wall 90°.
- 10 – Blank - Non Paint Spray.



Bruce Mahrenholz, Conformity Assessment Director
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

