

Certificate of Compliance

Certificate Number:

E494315

Report Reference:

E494315-20240326

Issue Date:

2024-04-24

Issued to:

Red Sky Lighting LLC

9370 Pittsburgh Ave

Rancho Cucamonga, CA, US, 91730-5557

This certificate confirms that representative samples of:

LUMINAIRES FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Models

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

UL 844, Luminaires for Use in Hazardous (Classified) Locations**CSA C22.2 No. 137, Electric Luminaires for Use in Hazardous Locations**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch

UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number: E494315
Report Reference: E494315-20240326
Issue Date: 2024-APRIL-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D, Luminaires, Models:

MDX [a],

[a] followed by -15L, -20L, -30L, -40L, -50L, -60L or -70L; followed by -100-277 or -347-480; followed by -65K, -57K, -5K, -4K, -3K or -27K; followed by Blank, -HAR or -XXX; followed by -30, -40, -60, -90, -120, -T1, -T2, -T3, -T4 or -T5; followed by -H2 or -HS; followed by -CG or -CP; followed by -GRY, -BLK, -WHT or -BRZ; followed by -PND, -SYK or -AYK.

Class II, Division 1, Groups E, F and G, Luminaires:

MDX [b]

[b] followed by -15L, -20L, -30L, -40L, -50L, -60L or -70L; followed by -100-277 or -347-480; followed by -65K, -57K, -5K, -4K, -3K or -27K; followed by Blank, -HAR or XXX; followed by -30, -40, -60, -90, -120, -T1, -T2, -T3, -T4 or -T5; followed by -H2 or -HS; followed by -CG; followed by -GRY, -BLK, -WHT or -BRZ; followed by -PND, -SYK or -AYK.